

EXHIBITION HALLS

IN ACCORDANCE WITH 527 CMR 21.00 MASSACHUSETTS DEPARTMENT OF PUBLIC SAFETY,

OFFICE OF
THE
DEPUTY FIRE CHIEF



44 VAN DEENE AVENUE
(413) 732-2650

WEST SPRINGFIELD, MASSACHUSETTS 01089

BOARD OF FIRE PREVENTION, NO FLAMMABLE DECORATIONS, INCLUDING TABLE AND WALL COVERINGS, SHALL BE USED IN A PLACE OF ASSEMBLY.

1. All fabrics used as back drops and/or table coverings must be flame retardant.
2. Flammable liquids and gasses are not allowed in the buildings.
3. No devices utilizing an open flame shall be allowed.
4. Batteries on all vehicles must be disconnected.
5. Vehicle fuel tanks shall have only the minimum amount of fuel necessary.
6. Fuel filler caps must be locked or secured with tape to prevent the public from removing them.
7. Vehicle engines shall not be started and run at any time while the building is open to the public.
8. All exits shall remain free and clear at all times.
9. All fire lanes shall remain free and clear at all times.
10. All aisles shall be a minimum 10' in width and shall remain free and clear at all times.
11. All fire extinguishers and other fire protection equipment shall be accessible at all times.
12. No signs, decorations or products shall be attached to any part of any sprinkler system.
13. NO PAPER, TRASH, CARDBOARD BOXES, OR ANY OTHER COMBUSTIBLE MATERIALS WILL BE STORED IN THE UTILITY CORRIDORS (*BEHIND THE BOOTHS*).

LASER EXHIBITS

1. Shielding from chips, sparks, etc. All equipment shall be set on a non-combustible surface. Said surface shall extend 36" in all directions beyond the perimeter of the equipment.
2. Shielding shall also be provided to prevent chips or sparks from coming in contact with anyone observing or passing by any operating equipment.
3. All particles or debris accumulated by the cutting process shall be cleaned from under and around the machine at the end of each day, or sooner, if necessary.
4. All operating machinery shall have an exhaust system to safely evacuate fumes or vapors that are generated.
5. Any machine which is designed and equipped with an automatic extinguishing system shall have that system on line and functional when the machine is operating.
6. Whenever a machine is operating there shall be a person knowledgeable with the operation of that machine within the display or booth area.
7. All displays with equipment operating shall have an appropriate size and type fire extinguisher within the booth.
8. No flammable gasses or liquids are allowed in the building.
9. Cylinders of non-flammable compressed gasses shall be secured in an upright position.

The fire prevention regulations listed above and any and all others not contained herein shall be strictly adhered to.